

## Risk Assessment (ladder selection only)

Height of works (or ceiling)?	
Activity type?	

**Can task be undertaken with your ladder & comply with the following at all times?**

No.	Description	Yes	No
1	Three points of contact at all times during access & egress.	<input type="checkbox"/>	<input type="checkbox"/>
2	Is ground level & suitable for ladder use.	<input type="checkbox"/>	<input type="checkbox"/>
3	Never climb higher than the third rung from the top of the ladder.	<input type="checkbox"/>	<input type="checkbox"/>
4	Limit the climb to allow for a secure hold while working from ladder ie worker can grasp the ladder near waist height.	<input type="checkbox"/>	<input type="checkbox"/>
5	Task allows body to work between stiles.	<input type="checkbox"/>	<input type="checkbox"/>
6	Ladder to be placed that permits the worker to face towards the ladder.	<input type="checkbox"/>	<input type="checkbox"/>
7	Task can be done without leaning over the side of ladder.	<input type="checkbox"/>	<input type="checkbox"/>
8	Task does not require excessive pulling or pushing.	<input type="checkbox"/>	<input type="checkbox"/>
9	Ladder rating & type to suit task eg; electrical work.	<input type="checkbox"/>	<input type="checkbox"/>

*Must comply with all items or an alternative method of height access obtained eg; scaffold, scissor lift or platform ladder. Ladders should always be footed.*

**If works are to be conducted in a public area of the terminal grounds solid barricades sufficient to prevent access from members of the public and in particular children must be used at all times in addition to an independent spotter.**

Name:	Sign:
Company:	Date: